



PICTURE 1
1 1/2" = 1'-0"

D1



PICTURE 2
1 1/2" = 1'-0"

D2



PICTURE 3
1 1/2" = 1'-0"

D3




PICTURE 4
1 1/2" = 1'-0"

D4



PICTURE 5
1 1/2" = 1'-0"

B1



PICTURE 6
1 1/2" = 1'-0"

B2



PICTURE 7
1 1/2" = 1'-0"

B3




PICTURE 8
1 1/2" = 1'-0"

B4

EXISTING CONDITION NOTES

1. REPAINT ALL INTERIOR WALLS. NOTE EXPOSED BRICK WALLS AT EXTERIOR WALL IN OPEN OFFICE AREA.
2. REPLACE ALL CEILING TILES (IN DECENT SHAPE OVERALL). NOTE EXISTING GYPSUM BOARD CEILING IS STILL ABOVE SUSPENDED CEILING AT BOTTOM OF TRUSSES.
3. REPLACE LIGHTING THROUGHOUT.
4. VCT FLOORS IN GOOD SHAPE, HOWEVER, ARE SHOWING SIGNS OF WEAR (EDGES TURNING UP). DETERMINE IF THIS IS A MOISTURE ISSUE.
5. REFINISH WOOD DOORS.
6. PROVIDE WOMEN'S TOILET ADJACENT EXISTING.
7. REPLACE HVAC SYSTEM.
8. BUILDING CURRENTLY HAS LIMITED DATA AND POWER. PROVIDE ADDITIONAL POWER AND DATA DROPS ALONG EXTERIOR WALLS FOR FUTURE FLEXABILITY. MAXIMIZE WHAT CAN BE ADDED BASED ON EXISTING BUILDING SYSTEMS.
9. BUILDING DOES NOT HAVE FIRE SPRINKLER SYSTEM.
10. SEAL EXTERIOR BRICK WALL WITH CLEAR MASONRY SEALER.
11. NOTE THAT WALLS ARE PAINTED WITH OIL BASED PAINT.




EXISTING CONDITIONS FLOOR PLAN -
BUILDING 26
1/8" = 1'-0"



SCALE: 1/8" = 1'-0"

SYMBOL	DESCRIPTION	DATE	APPROVED



FINAL
SUBMITTAL
OCTOBER 13, 2015



APPROVED
FOR COMMANDER NAVFAC
ACTIVITY
SATISFACTORY TO DATE
DES JB DRW DS CHK DE
PM
BRANCH MANAGER
CHIEF ENG/ARCH
FIRE PROTECTION

DEPARTMENT OF THE NAVY	NAVAL FACILITIES ENGINEERING COMMAND	NAVAL STATION - NORFOLK, VIRGINIA
NOPT	MCB CAMP LEJEUNE	JACKSONVILLE, NORTH CAROLINA
P-1346	SIMULATOR CENTER AND RANGE CONTROL	BUILDING 26

SCALE:	GRAPHIC
PROJECT NO.	1168092
CONSTR. CONTR. NO.	N40082-10-D-5301
NAVFAC DRAWING NO.	

SHEET	1	OF
-------	---	----

A-104